

Customer: Langlade Springs LLC NLS Project: 257828

Project Description: Product Water

Project Title: Template: 525DNRL.ISQ Printed: 04/28/2016 17:04

Sample: 913285 Plant (SOC) Collected: 04/04/16 Analyzed: 04/12/16 - Analytes: 24

ANALYTE NAME	RESULT	UNITS	DIL	LOD	LOQ	MCL	Note
Alachlor (Lasso)	ND	ug/L	1	0.015	0.050	2	
Aldrin	ND	ug/L	1	0.015	0.049		
Atrazine	ND	ug/L	1	0.024	0.081	3	
Benzo[a]pyrene	ND	ug/L	1	0.0085	0.027	.2	
Butachlor	ND	ug/L	1	0.025	0.082		
Chlordane alpha	ND	ug/L	1	0.016	0.053		
Chlordane gamma	ND	ug/L	1	0.018	0.061		
Cyanazine	ND	ug/L	1	0.039	0.13		
Deethylatrazine	ND	ug/L	1	0.027	0.091		LC
Deisopropylatrazine	ND	ug/L	1	0.21	0.70		LC
Dieldrin	ND	ug/L	1	0.020	0.067		
Di(2-ethylhexyl)adipate	ND	ug/L	1	0.60	1.2	400	
Di(2-ethylhexyl)phthalate	ND	ug/L	1	0.60	2.0	6	
Endrin	ND	ug/L	1	0.0090	0.029	2	
Heptachlor	ND	ug/L	1	0.019	0.063	.4	
Heptachlor epoxide	ND	ug/L	1	0.015	0.049	.2	
Hexachlorobenzene	ND	ug/L	1	0.019	0.063	1	
Hexachlorocyclopentadiene	ND	ug/L	1	0.036	0.12	50	
BHC gamma (Lindane)	ND	ug/L	1	0.0075	0.024	.2	
Methoxychlor	ND	ug/L	1	0.016	0.054	40	
Dual (Metolachlor)	ND	ug/L	1	0.011	0.037		
Metribuzin (Sencor)	ND	ug/L	1	0.019	0.065		
Propachlor	ND	ug/L	1	0.014	0.047		
Simazine	ND	ug/L	1	0.049	0.17	4	
1,3-Dimethyl-2-Nitrobenzene (SURR)	102%						S
Triphenylphosphate (SURR)	118%						S
Perylene-d12 (SURR)	107%						S

NOTES APPLICABLE TO THIS ANALYSIS:

S = This compound is a surrogate used to evaluate the quality control of a method.

LC = Laboratory control spike recovery was outside QC limits.

Deethylatrazine recovered below QC limits.

Deisopropylatrazine recovered below QC limits.